

# NORTHWEST LABORATORIES *of Seattle, Incorporated*

ESTABLISHED 1896

*Technical Services for: Industry, commerce, Legal Profession & Insurance Industry*

241 South Holden Street • Seattle, WA 98108-4359 • Phone: (206) 763-6252 • Fax: (206) 763-3949 [www.nwlabsl896.com](http://www.nwlabsl896.com)

December 9, 2010

Quick & Easy Concrete, Inc.  
P.O. Box 1546  
Woodinville, WA 98072

**Attn: Cliff Wilson**

Re: Chloride Ion Content  
AASHTO T260  
N.W. Labs Report #**E84621**

Dear Mr. Wilson:

Per your request, the submitted concrete core was tested for chloride ion content per AASHTO T260. The core was aged for 28 days prior to testing.

The following results were obtained.


**Analysis:** Per ASSHTO T260

<u>Sample ID</u>	<u>Results (%)</u> <u>by weight of concrete</u>	<u>Result (%)</u> <u>by weight of cement</u>	<u>Specified</u>
11-9-10 core	0.005	0.042	0.10% max

**Note:** The water content was assumed to be 47% of weight of cement.

Sincerely,

NORTHWEST LABORATORIES, INC.



Omar Simon, Chemist

nbe

[www.nwlabsl896.com](http://www.nwlabsl896.com)  
[osimon@nwlabsl896.com](mailto:osimon@nwlabsl896.com)